

[19] Patents Registry
The Hong Kong Special Administrative Region
香港特別行政區
專利註冊處

[11] 1149857 B
EP 2240993 B1

[12]

STANDARD PATENT SPECIFICATION
標準專利說明書

[21] Application no. 申請編號
11103999.2

[51] Int. Cl.
H02J

[22] Date of filing 提交日期
20.04.2011

[54] BACKUP POWER SYSTEM AND METHOD
備用電源系統和方法

[30] Priority 優先權
07.02.2008 US 12/027,682

[43] Date of publication of application 申請發表日期
14.10.2011

[45] Date of publication of grant of patent 批予專利的發表日期
09.08.2019

[86] International application no. 國際申請編號
PCT/US2009/033334

[87] International publication no. and date 國際申請發表編號及日期
WO2009/100295 13.08.2009

EP Application no. & date 歐洲專利申請編號及日期
EP 09709004.7 06.02.2009

EP Publication no. & date 歐洲專利申請發表編號及日期
EP 2240993 20.10.2010

Date of grant in designated patent office 指定專利當局批予專利日期
24.10.2018

[73] Proprietor 專利所有人
AINET REGISTRY LLC
11700 MONTGOMERY ROAD
BELTSVILLE, MARYLAND 20705
UNITED STATES/UNITED STATES OF AMERICA

[72] Inventor 發明人
JAIN, Deepak K.

[74] Agent and / or address for service 代理人及/或送達地址
CLT Patent & Trademark (H.K.) Ltd.
Unit 09, 34/F.
Office Tower, Convention Plaza
No. 1 Harbour Road
Wanchai HONG KONG

(19)



(11)

EP 2 240 993 B1

(12)

EUROPEAN PATENT SPECIFICATION

(45) Date of publication and mention
of the grant of the patent:

24.10.2018 Bulletin 2018/43

(51) Int Cl.:

H02J 9/06 ^(2006.01)

(86) International application number:

PCT/US2009/033334

(21) Application number: **09709004.7**

(22) Date of filing: **06.02.2009**

(87) International publication number:

WO 2009/100295 (13.08.2009 Gazette 2009/33)

(54) BACKUP POWER SYSTEM AND METHOD

RESERVESTROMSYSTEM UND VERFAHREN

SYSTÈME D ALIMENTATION DE SECOURS ET PROCÉDÉ

(84) Designated Contracting States:

**AT BE BG CH CY CZ DE DK EE ES FI FR GB GR
HR HU IE IS IT LI LT LU LV MC MK MT NL NO PL
PT RO SE SI SK TR**

(72) Inventor: **JAIN, Deepak K.**

Beltsville, Maryland 20705 (US)

(30) Priority: **07.02.2008 US 27682**

(74) Representative: **Giavarini, Francesco et al**

Zanoli & Giavarini S.p.A.

Via Melchiorre Gioia, 64

20125 Milano (IT)

(43) Date of publication of application:

20.10.2010 Bulletin 2010/42

(56) References cited:

WO-A-95/34933

US-A- 5 642 004

US-A- 6 134 124

US-A1- 2005 184 594

US-A1- 2006 192 433

(73) Proprietor: **AiNET Registry LLC**
Beltsville, MD 20705 (US)

Note: Within nine months of the publication of the mention of the grant of the European patent in the European Patent Bulletin, any person may give notice to the European Patent Office of opposition to that patent, in accordance with the Implementing Regulations. Notice of opposition shall not be deemed to have been filed until the opposition fee has been paid. (Art. 99(1) European Patent Convention).

Description

BACKGROUND

[0001] This application is generally directed to a stored energy system and method and, in one or more embodiments, is particularly directed to a backup power system, a controller useful therein, and a method for providing backup power having application, for example, in support of a computer system or other devices that require a stable source of electrical power for continuous, uninterrupted operation and protection of sensitive electronic components. Other applications may be found in the utility industry in which various alternative types of power sources may be utilized to meet load requirements, e.g., solar, wind, battery, diesel or gas turbine generators in combination with conventional steam turbine generators.

[0002] US5642004A discloses a power supply for standby circuits for an electrical consumer which separates both the electrical consumer and the power supply from the mains when in standby mode. The necessary power is supplied by a storage component backed up by an alternative voltage source. A voltage detector monitors the state of charge of the storage component and connects the circuit of the power unit to the mains as necessary. This power supply is suitable both for standby circuits of electrical consumers and for devices themselves or simply for control components and remote-control receivers on devices. Since a power unit is only connected to the mains when necessary, considerable energy savings are achieved.

[0003] Conventional emergency and redundant power systems supporting offline or near-line cogeneration or emergency standby generation are generally limited in their ability to meet end-users' goal of continuous, interruptible power. Such conventional systems typically employ a primary utility feed, a transfer switch and, on the other switched side of the transfer switch, a generator powered by a prime mover, e.g., a diesel engine.

[0004] The output of the transfer switch typically feeds an uninterruptible power supply (UPS) or other stored energy system (e.g., a mechanical flywheel). Transfer switch logic may be designed to power up and switch to the generator when the utility mains fail for longer than a specified amount of time. After utility power has been restored for a sufficient period of time, the transfer switch is designed to switch back to the utility mains or primary source of power. The stored energy system may provide power and energy shaping in the time gaps or interruptions between generator fire-up, as well as during the transfer switch switching delay.

[0005] As the electrical supply grid becomes more complex with multiple energy providers, multiple grids, and increased loading, a number of failures less than a total outage during a single fault event often occur. For example, during failure of a transformer or during a series of lightning strikes in the power grid, power may intermittently disappear and reappear on the utility feed several

times within a short period of time. Such intermittent power outages may be a precursor to a total power failure, or may damage electronic equipment fed by the grid.

[0006] This kind of cycling effect can not only result in power spikes that can damage sensitive electronic equipment, it can drain a stored energy system without allowing sufficient time to recharge between hits. If this sort of event occurs and the stored energy system does not have enough energy to handle the delay for the generator to achieve full power, the end-user's power source will see an interruption and potential damage to components or interruption of service often results.

[0007] Further, the advancement of "green" or renewable energy technologies poses challenges in integrating these sometimes intermittent sources of power into a stable power grid.

SUMMARY

[0008] The invention is defined by a backup power system with the technical features of independent claim 1, and a corresponding method with the steps of claim 11. Alternative embodiments are defined in the dependent claims.

[0009] Among other things, this disclosure provides embodiments of a system and method that provides a source of backup or emergency power to a device or system in which stored energy levels of a stored energy component are monitored, for example, an uninterruptible power supply (UPS) or other electro-chemical arrangement (e.g., battery or fuel-cell), or an electro-mechanical flywheel arrangement. In other embodiments, a controller that is useful in controlling emergency or backup transfer of power to a load is disclosed, as is a computer program product that contains a computer-readable medium with computer instructions thereon that are useful in programming a computer or processor to carry out functions that control the emergency or backup transfer of power to a load.

[0010] In one exemplary embodiment using a generator as a secondary power source, a stored energy level in the stored energy component is compared against two thresholds. The first threshold may be defined as an amount of energy required by the device or system for which backup power is being provided (plus an additional margin, as desired) over the period of time that it takes a backup generator, for example, to reach full output. Alternatively, the first threshold may be expressed as the time that it takes the backup generator to come up to speed and reach full output capacity.

[0011] A second threshold may be defined as a number greater than the first threshold, and which is selected to minimize a number of starts and stops of the generator. Alternatively, the margin provided by the first threshold may be defined as a safe minimum level for operating the stored energy system without causing damage.

[0012] The system may include a data communication system between the stored energy system and the trans-

fer switch and/or the generator or other secondary power source. The system thus only starts the generator when it is necessary, and is also capable of starting the generator in advance of a predicted need, thus providing uninterrupted power.

[0013] In one embodiment, a backup power system may include a secondary power source; a stored energy component capable of storing energy therein; and a controller in data communication with the secondary power source and the stored energy component. The controller may be configured to compare a measured energy level of energy stored within the stored energy component against a first threshold relating to a maximum time necessary for the secondary power source to at least reach a predetermined minimum output level. Further, the controller may be configured to compare the stored energy level to a second threshold greater than the first threshold. The second threshold may be selected so as to reduce a number of on/off cycles of the secondary power source during periods of intermittent power fluctuation of the primary power source that are less severe than a prolonged full power loss by the primary power source. In a related aspect, the system may also include a transfer switch electrically connectable to a primary power source and electrically connected to the secondary power source. The controller may also be operatively connected to the transfer switch.

[0014] In another embodiment, a method of making backup power available for a load that receives normal power from a primary power source includes providing a secondary power source; providing a stored energy component; monitoring a stored energy level within the stored energy component; comparing the monitored stored energy level to a first threshold relating to a maximum time necessary for the secondary power source to at least reach a predetermined minimum output level; and comparing the stored energy level to a second threshold greater than the first threshold, said second threshold being selected so as to reduce a number of on/off cycles of the secondary power source during periods of intermittent power fluctuation of the primary power source that are less severe than a prolonged full power loss by the primary power source. In response to one or more comparison results, power may be selectively transferred to the load from one of the primary power source, secondary power source, and the stored energy component.

[0015] In another embodiment, a computer program product comprising a computer-readable readable medium has computer instructions thereon which, when executed by a computer, cause various functions to be carried out by the computer, including, for example to compare a stored energy level in a stored energy element to a first threshold relating to a maximum time necessary for a secondary power source to at least reach a predetermined minimum output level; to compare the stored energy level to a second threshold greater than the first threshold, said second threshold being selected so as to reduce a number of on/off cycles of the secondary power

source during periods of intermittent power fluctuation of a primary power source that are less severe than a prolonged full power loss by the primary power source; and in response to one or more comparison results, generate one or more signals useful in commanding a selective transfer of power to a load from one of the primary power source, the secondary power source, and the stored energy component.

[0016] In another embodiment, a controller useful in selecting a source of power provided to a load includes one or more processors arranged to receive one or more parameters relating to a primary power source, a secondary power source, and a stored energy component. A memory may be operatively connected to the processor which may be configured, *inter alia*, to compare a measured energy level representing energy stored within the stored energy component against a first threshold stored in the memory. The first threshold may relate to a maximum time necessary for the secondary power source to at least reach a predetermined minimum output level. The processor may further compare the measured energy level to a second threshold stored in the memory. The second threshold may be greater than the first threshold and selected so as to reduce a number of on/off cycles of the secondary power source during periods of intermittent power fluctuation of the primary power source that are less severe than a prolonged full power loss by the primary power source. In response to one or more comparison results, the processor may selectively provide one or more signals that command power to be provided or transferred to the load from one of a primary power source, the secondary power source, and the stored energy component.

[0017] In another aspect of this embodiment, the processor may selectively command power to be provided to the stored energy component via one or more control signals if the measured energy level is less than the second threshold.

BRIEF DESCRIPTION OF THE DRAWINGS

[0018]

FIG. 1 provides a block diagram of an exemplary embodiment of a backup power system;

FIG. 2 provides a process flowchart illustrating exemplary logical flow of a method for providing backup power using the system of FIG. 1;

FIG. 3A graphically depicts various thresholds useful in the system of FIG. 1 and the method of FIG. 2, and FIG. 3B provides an alternative representation of various thresholds useful in the system of FIG. 1 and the method of FIG. 2;

FIG. 4 illustrates an alternative embodiment that incorporates sources of intermittent power into the backup power system of FIG. 1; and

FIG. 5 provides a process flowchart illustrating exemplary logical flow of a method for providing backup

power using the system of FIG. 4.

DETAILED DESCRIPTION

[0019] Turning now to the Drawings, FIG. 1 provides a block diagram of an embodiment of a backup power system 100. The solid lines represent power flow (with unidirectional flow) and the dashed lines represent data and/or control signal paths (with exemplary unidirectional or bi-directional data flow directions indicated by the arrows). Power mains 110 may represent utility power or some other source of primary ("normal") power for load 125, e.g., single or 3-phase AC power at a standard voltage. For some applications, primary power could be in the form of DC power. Power mains 110 may be connected to load 125 through transfer switch 120. In a normal mode of operation, transfer switch 120 may directly connect power mains 110 to load 125 without further processing or switching.

[0020] Controller 130 may be arranged to monitor various parameters and voltages in system 100, and may be implemented by a personal computer, or some other known processor or multiprocessor configuration running computer software or firmware code appropriate to carry out the various control and data functions described herein. Data and/or control signals may be communicated between transfer switch 120 and controller 130 over link 131. The various control/data signal interconnections represented by links 131 through 138 may be made by conventional wired interfaces, or may be implemented by known wired or wireless techniques. Alternatively, controller 130 may be implemented in analog form appropriate in sensing and/or setting various thresholds of interest, for example, by use of one or more potentiometers and comparator circuitry.

[0021] Memory 145 may be coupled to controller 130 in a known manner for storing data representing, for example, various operating parameters of system 100, including, but not limited to an energy storage condition of stored energy element 150, a status of secondary power source 140, and particular threshold values useful in making power transfer decisions. In the case of an analog implementation, memory 145 might not be necessary or desired.

[0022] Secondary power source 140 is shown connected to transfer switch 120, and may be a standby generator (e.g., a common diesel or gas turbine generator), or an electro-chemical arrangement such as a battery with appropriate conversion circuitry to convert from a DC voltage to an appropriate AC and/or DC voltage, as needed. Control/data path 138 may be used to control secondary power source 140, and/or to obtain status information from secondary power source 140, which may be used by transfer switch 120, or which may be relayed directly or indirectly to controller 130 via link 131.

[0023] Stored energy element 150 may be coupled to transfer switch 120 (e.g., through converter 160A), and may be viewed as an "emergency" backup power source

in the event that the secondary power source is unavailable to provide power to load 125 when primary power (e.g., power mains 110 or other source of "normal" power) is unavailable or unreliable. Alternatively, the output of converter 160A may be directly coupled to load 125 and not be directly connected to transfer switch 120 (not shown in FIG. 1). Continuing with FIG. 1, one or two-way data/control signal communication between controller 130 and stored energy element 150 may be provided by link 134. Stored energy element 150 may include a flywheel or other kinetic energy system, or it may be a battery system such as an uninterruptible power supply (UPS). Depending on the type of energy stored in stored energy element 150, converters 160A and 160B may be useful to convert the form of energy stored in stored energy element 150 into a form that is useful for load 125.

[0024] For example, if stored energy element 150 is a flywheel that "stores" the kinetic energy of the rotating flywheel, converter 160A may include a generator arrangement configured to convert kinetic energy of the flywheel into electric power in a form that is useful for load 125 by AC-DC or AC-DC-AC conversion, depending upon the frequency and voltage required for load 125. If stored energy element 150 is a battery, for example, converter 160A may be a DC-AC (or DC-AC-DC) converter arrangement to convert DC from the battery into AC or DC power as necessary to satisfy the requirements of load 125. Converter 160A may provide or exchange data and/or control signals with controller 130 via link 132.

[0025] Converter 160B may be used when restoring the energy in stored energy element 150 to a desired level. For example, if stored energy element 150 is a battery and primary power is AC power, converter 160B may convert AC power received through transfer switch 120 to DC power such that the battery can recharge. If stored energy element 150 is a flywheel, for example, then converter 160B may include circuitry and/or components that would act to restore the rotational speed of the flywheel up to a nominal idle or standby speed so that the kinetic energy "stored" in the spinning flywheel is at a desired level. Converter 160B may provide or exchange data and/or control signals with controller 130 via link 135 and with transfer switch 120 via link 137.

[0026] Monitor 170 may be used to monitor the level of energy stored in stored energy element 150, and may obtain operating parameters of stored energy element 150 via link 136. Monitor 170 may be built-in or integral with stored energy element 150, with a conventional data interface/link 136. If stored energy element 150 is a battery, for example, monitor 170 may be configured to assess the remaining charge in the battery, and to communicate various system and/or component parameters with controller 130 via link 133.

[0027] A display and various input/output (I/O) devices may be interfaced with controller 130 in a known way to display and/or input information regarding various components and/or parameters of system 100 or to reconfigure system 100, as represented by display and I/O 180,

interfaced with controller 130 via link 139. For example, various thresholds useful in making power transfer decisions may be input into memory 145 via controller 130 and representations thereof may be displayed to an operator using I/O functionality in display and I/O 180.

[0028] Various aspects of the system embodiment above will now be discussed with respect to FIG. 1. In one aspect, backup power system 100 includes secondary power source 140, stored energy component 150 capable of storing energy in one form or another, and controller 130 which is in data communication (e.g., using data/control lines 131, 134) with secondary power source 140 and stored energy component or element 150.

[0029] Controller 130 may be configured, *inter alia*, to compare a measured energy level of energy stored within stored energy component 150 against a first threshold (e.g., E1 or T1) relating to a maximum time necessary for secondary power source 140 to at least reach a predetermined minimum output level. Further, controller 130 may be configured to compare the stored energy level to a second threshold (e.g., E2 or T2) greater than the first threshold. The second threshold may be selected so as to reduce a number of on/off cycles of secondary power source 140 during periods of intermittent power fluctuation of primary power source/power mains 110 that are less severe than a prolonged or complete power loss by primary power source 110.

[0030] In this embodiment, controller 130 may be controlled and arranged so as to selectively provide power to external load 125 from one of primary power source 110, secondary power source 140, and stored energy component 150 in response to one or more comparison results made by controller 130, e.g., comparing the stored energy level to one or more predetermined thresholds, or to thresholds that are changed in response to dynamic events occurring in or otherwise affecting system 100. In a related aspect, controller 130 and transfer switch 120 may be configured to provide power to external load 125 from stored energy component 150 during periods of intermittent power fluctuation, for example, when a voltage of power mains 110 is fluctuating or is otherwise abnormal, *i.e.*, where the voltage is spiking and/or sagging.

[0031] In a further aspect of this embodiment, transfer switch 120 is capable of being electrically connected to primary power source 110 and secondary power source 140, and operation of transfer switch 120 may be directly or indirectly controlled or commanded by controller 130 so as to provide power to external load 125 from a selected one of primary power source 110, secondary power source 140, and stored energy component 150.

[0032] In another aspect, controller 130 and transfer switch 120 are configured to selectively restore the stored energy level in stored energy component 150 to at least the second threshold in response to a comparison result indicating that the stored energy level is less than the second threshold. This may be accomplished, for example, by operatively connecting secondary power source

140 to stored energy component 150 or, in another aspect, the stored energy level in stored energy component 150 may be restored, at least in part, by operatively connecting primary power source 110 to stored energy component 150 (via transfer switch 120, for example).

[0033] In a further aspect, controller 130 and transfer switch 120 are configured to selectively restore the stored energy level in stored energy component 150 to a predetermined energy level greater than the second threshold, *i.e.*, to a level closer to a "full" level and, this may be done by using secondary power source 140. This could be considered to be a "third threshold". Additional thresholds may be used to suit the particular operational needs for the system. In another aspect of this embodiment, secondary power source 140 may provide power to external load 125 through transfer switch 120.

[0034] Further, and in response to an indication that the stored energy level in stored energy component 150 is not greater than the first threshold, the controller may be configured to energize secondary power source 140.

[0035] Additionally, controller 130 may be configured to energize secondary power source 140 if primary power source 110 is not available, or is deemed to be unreliable or providing power of unacceptable quality for a particular type of load 125 being energized.

[0036] In another aspect, and in response to an indication that the stored energy level is greater than the second threshold, controller 130 may be configured to place secondary power source 140 in a standby mode.

[0037] System 100 may also include memory 145 operably connected to controller 130, and configured to at least store the first and second thresholds. Further, system 100 may also include a display and at least one input/output device operably connected to said controller, e.g., a keyboard and/or mouse, and other conventional peripheral equipment.

[0038] In an embodiment where secondary power source 140 is a generator, and assuming that the generator subsystem were energized or activated in advance of another outage (after stored energy component 150 fell below a first threshold), and allowed to stay running until stored energy component 150 reached a minimum acceptable level of power (*i.e.*, a second threshold greater than the first threshold) a user's exposure to and concerns relating to power interruption in load 125 approaches zero.

[0039] FIG. 3B depicts an exemplary implementation of the two thresholds mentioned above. The first threshold, e.g., T1, could be defined as the time it takes the generator subsystem to reach full potential plus some sufficient margin (e.g., "V_{SAFE}"). Alternatively, this additional margin could be defined as a safe minimum level for stored energy system 150 to be maintained at without causing damage to a connected load 125.

[0040] The second threshold, e.g., T2, could be defined as a time greater than T1 and designated as 100% capacity of stored energy system 150 (e.g., "V_{FINAL}"), but could be judiciously chosen to minimize the number of

starts/stops of the generator subsystem. For example, if T2 is chosen to be too close in value to T1, the generator subsystem, or more broadly, secondary power source 140, will be cycled on and off too frequently, leading to possible degradation of its capacity to be available when secondary power is needed for load 125, as well as causing undesirable wear and tear on various electro-mechanical components that might be contained therein.

[0041] FIG. 3A provides an alternative view of the first and second thresholds. In this depiction, measured in units of energy, E1 and E2, E1 corresponds to the minimum energy necessary to be stored in stored energy element 150 for provision to load 125 during the time that the generator subsystem takes to reach a full potential plus some sufficient margin, for example, " V_{SAFE} ". E2 corresponds to an energy level necessary to be stored in stored energy element 150 for possible provision to load 125 during the longer period of time that the generator subsystem may take to reach a final voltage, for example, " V_{FINAL} ".

[0042] FIG. 3A goes on to illustrate that the thresholds E1 and E2 (T1 and T2) may be dynamic values, depending on a particular load 125 being supplied, the history or future projections of the stability, availability of power mains 110, or due to degradation of secondary power source 140 and/or stored energy element 150, or some other quantifiable degrading effect on the conversion efficiency of system 100 in a backup power mode. Dynamic thresholds E1' and E2' illustrate an increase of the threshold related to the occurrence of an event at time T_{EVENT} , which has stabilized at a higher threshold value at later time T'_{EVENT} . The threshold values may increase or decrease, and may be input into system 100 by display I/O device(s) 180 due to an event in system 100, gradual degradation of system components, or by operator preference.

[0043] Another embodiment of this disclosure is provided in FIG. 2, in which a method for providing backup power is illustrated. In this embodiment, the process starts at step S210, and proceeds to step S220 where a decision is made as to whether the level of stored energy (SE) in stored energy element 150 is greater than first threshold, E1. If not, then step S230 energizes secondary power system 140 even if primary power 110 is available. The stored energy level SE could be restored by primary power 110 if such power is available, without the need for energizing secondary power system 140. However, to ensure that sufficient energy reserve is stored in stored energy element 150 to provide sufficient margin for maintaining system reliability, all available sources of power may be used to increase reliability. For example, even if primary power 110 is currently available, secondary power system 140 may still be energized to increase the energy stored in stored energy element 150 above threshold E1. This protocol helps provide a safety margin by increasing the probability that energy sufficient to start secondary power system 140 is provided to stored energy element 150 and ensures that secondary power is

available during the time that $SE < E1$.

[0044] If $SE > E1$, then a further determination is made at step S240 whether $SE > E2$. If this logical condition is true, and if primary power is available, then secondary power system 140 is returned to a "standby" condition at step S250. Otherwise, *i.e.*, if $E1 < SE \leq E2$, then, at step S260, energy is continued to be restored to stored energy element 150 if either primary or secondary power is available. The process repeats at step S270 by returning to step S210.

[0045] In related aspects of this embodiment, and as illustrated by the flowchart of FIG. 2, a method of making backup power available for a load that receives normal power from a primary power source 110 includes providing secondary power source 140; providing stored energy component 150; monitoring a stored energy level within stored energy component 150; comparing the monitored stored energy level to a first threshold (E1) relating to a maximum time and/or energy level necessary for the secondary power source to at least reach a predetermined minimum output level; and comparing the stored energy level to a second threshold (E2) greater than the first threshold (E1). The second threshold E2 may be selected so as to reduce a number of on/off cycles of secondary power source 140 during periods of intermittent power fluctuation of primary power source 110 that are less severe than a prolonged full power loss by the primary power source. Further, and in response to one or more comparison results, power may be selectively transferred to load 125 from one of the primary power source 110, secondary power source 140, and stored energy component 150.

[0046] In a further aspect of the embodiment, power may be selectively transferred to load 125 from stored energy component 150 during periods of intermittent power fluctuation. Further, the stored energy level in stored energy component 150 may be selectively restored to at least the second threshold in response to a comparison result indicating that the stored energy level is less than the second threshold. The stored energy level in stored energy component 150 may be selectively restored by transferring power from secondary power source 140 to stored energy component 150. Alternatively, the stored energy level in stored energy component 150 may be selectively restored by transferring power from primary power source 110 to stored energy component 150, and may be further restored to a predetermined energy level greater than the second threshold, for example, to full capacity or to some other level greater than the second threshold and less than full capacity.

[0047] In a related aspect, power may be selectively transferred to load 125 from secondary power source 140. An aspect of the method may include energizing the secondary power source in response to an indication that said stored energy level is not greater than the first threshold, and/or the secondary power source may be energized if normal power received from the primary power source is not available. In a further aspect, the

secondary power source may be in a standby mode in response to an indication that the stored energy level is greater than the second threshold.

[0048] In one or more embodiments, the first and second thresholds may be stored in a memory operably connected to a processor, and a status or other system-related information may be displayed, for example, an operational status of the secondary power source and the stored energy component may be displayed. As mentioned above, in the case of an analog controller 130, the thresholds may be implemented by appropriate analog circuitry that establishes the desired thresholds in terms of voltages, for example.

[0049] In another embodiment, computer instructions may be encoded onto a computer-readable medium having computer-readable program code embodied therein (e.g., floppy disk, CD, or firmware) for causing a computer to control power transfer to a load from one or more sources of power. Upon execution by the computer, the computer-readable code may cause the computer, *inter alia*, to compare a stored energy level in a stored energy element to a first threshold relating to a maximum time necessary for a secondary power source to at least reach a predetermined minimum output level. In addition, the computer may also compare the stored energy level to a second threshold greater than the first threshold. The second threshold may be selected so as to reduce a number of on/off cycles of the secondary power source during periods of intermittent power fluctuation of a primary power source that are less severe than a prolonged full power loss by the primary power source. In response to one or more comparison results, the computer may then be instructed to generate one or more signals useful in commanding a selective transfer of power to a load from one of the primary power source, the secondary power source, and the stored energy component. In a further aspect of this embodiment, the computer code may cause the computer to monitor a stored energy level within the stored energy component.

[0050] In another embodiment, controller 130 is configured to be useful in selecting a source of power provided to load 125, and may include one or more processors arranged to receive one or more parameters relating to primary power source 110, secondary power source 140, and stored energy component 150. Memory 145 may be operatively connected to the processor, and the processor may be configured to compare a measured energy level representing energy stored within stored energy component 150 against a first threshold (e.g., T1 or E1) stored in memory 145.

[0051] As discussed above, the first threshold may relate to a maximum time necessary for secondary power source 140 to at least reach a predetermined minimum output level. The processor may also compare the measured energy level to a second threshold (e.g., E2 or T2) stored in memory. The second threshold may be greater than the first threshold and selected so as to reduce a number of on/off cycles of secondary power source 140

during periods of intermittent power fluctuation of primary power source 110 that are less severe than a prolonged full power loss by primary power source 110.

[0052] In response to one or more comparison results, the processor may selectively provide one or more signals that command power to be provided to load 125 from one of primary power source 110, secondary power source 140, and stored energy component 150. In another aspect of this embodiment, the processor may selectively command power to be provided to stored energy component 150 if the measured energy level is less than the second threshold.

[0053] Turning now to FIG. 4, an alternative embodiment of a backup power system is depicted in block diagram form. The system of FIG. 4 is similar in many respects to the system of FIG. 1, but with the addition of intermittent power sources, for example, wind power source 410 and solar power source 420. These renewable power sources are considered to be "intermittent" due to the likelihood that the sun and/or wind will not always be available to provide a significant or commercially useable amount of power. Although not shown, other types of "green" or renewable energy sources may be included in the system of FIG. 4.

[0054] In addition, depending on the overall system requirements or desired performance for a particular application, these alternative sources of energy may be capable of performing the functions of secondary power source 140, thus rendering secondary power source 140 optional or unnecessary.

[0055] Further, wind power source 410 and solar power source 420 are depicted as providing power/energy directly to stored energy element 150. However, these alternative intermittent power sources may be configured to provide power to the electrical grid through other conventional means (not shown), and not directly to stored energy element 150. In this variant embodiment, the intermittent power sources may or may not be available to restore energy to stored energy element 150 through alternative arrangements.

[0056] In one embodiment, intermittent power monitor/controller 430 may be operatively connected to wind power source 410 and solar power source 420 in order to monitor the operating status and power available from these intermittent power sources, and to selectively connect the output power of one or more of these power sources to stored energy element 150 after one or more user-defined criteria are met. Intermittent power monitor/controller 430 may be operatively connected via a network or data connection, for example, to controller 130 and memory 145.

[0057] A person with skill in the art would appreciate that a conversion between the type of power output by wind power source 410 and solar power source 420 to the type of energy stored in stored energy element 150 would likely need to be made. For example, a DC voltage produced by a photo-voltaic panel (one example of a solar power source) might need to be converted to an AC

voltage in order to be utilized or stored by stored energy element 150. Similarly, wind power source 410 may provide an AC output voltage at a different frequency and/or voltage than what might be needed by stored energy element 150. For simplicity, these various conversion devices are not illustrated in FIG. 4.

[0058] Alternatively, the functions performed by intermittent power monitor/controller 430 may be incorporated into controller 130 and/or monitor 170 with appropriate programming and data connections to wind power source 410 and/or solar power source 420, thus eliminating the need for a separate controller.

[0059] FIG. 5 provides a flow chart for a method of providing backup power using the system of FIG. 4. In this embodiment, the process starts at step S510, and proceeds to step S520 where a decision is made as to whether the level of stored energy (SE) in stored energy element 150 is greater than first threshold, E1. If not, then step S530 energizes secondary power system 140 even if primary power 110 is available. In addition, or alternatively, step S530 may also connect wind power source 410 and/or solar power source 420 (i.e., intermittent power sources) to stored energy element 150 if these one or more of these intermittent power sources are available to restore energy or "recharge" stored energy element 150.

[0060] In the case where primary power 110 is available, the secondary power system 140 may be energized to ensure that sufficient energy reserve is stored in stored energy element 150 to provide sufficient margin for maintaining system reliability. For example, even if primary power 110 is currently available, and if wind power source 410 and/or solar power source 420 are also available, optional secondary power system 140 may still be energized to increase the energy stored in stored energy element 150 above threshold $SE > E1$. This protocol helps provide a safety margin by increasing the probability that energy sufficient to start secondary power system 140 is provided to stored energy element 150, and ensures that secondary power is available during the time that $SE < E1$ given the likely intermittent nature of wind and solar power sources.

[0061] If $SE > E1$, then a further determination is made at step S540 whether $SE > E2$. If this logical condition is true, and if primary power is available, then secondary power system 140 is returned to a "standby" condition at step S550. Otherwise, i.e., if $E1 < SE \leq E2$, then, at step S560, energy may be restored to stored energy element 150 by wind power source 410 and/or solar power source 420, or other alternative energy source, if available. If an intermittent or alternative power source is not available, and if either primary or secondary power is available, energy may continue to be restored to stored energy element 150 at step S565. The process repeats at step S570 by returning to step S510.

[0062] In the embodiment of FIGS. 4 and 5, the stored energy level in stored energy component 150 may be selectively restored by either transferring power from

secondary power source 140 to stored energy component 150, by transferring power from primary power source 110 to stored energy component 150, or by intermittent power sources, e.g., wind power source 410 and/or solar power source 420, or combinations of these power sources. As in the embodiments of FIGS. 1 and 2, the stored energy level may be further restored to a predetermined energy level greater than the second threshold, for example, to full capacity or to some other level greater than the second threshold and less than full capacity.

[0063] In addition, controller 130 and/or intermittent power monitor/controller 430 may be configured to allow user preferences to be set for the type of power/energy source to be used in restoring energy to stored energy component 150. For example, as renewable energy sources become more commercially available and accepted into the power grid, wind and solar power sources may be given preference to restore the energy level in stored energy component 150, in contrast to more costly and polluting standby generators that may be used as secondary power source 140, e.g., gas turbine or diesel generators.

[0064] For example, the conventional grid or standby power system may be available when intermittent power sources are not available and the stored energy level is less than the first threshold, i.e., $SE < E1$. This embodiment provides the ability to only use "grid" or standby power generation when you actually need it, and the power system can survive multiple intermittent interruptions alternative energy sources without energizing conventional or standby generation capability. For example, if solar power becomes available before $SE = E1$, the conventional or standby power source will not need to be energized, and the SE system will regain the capability to restore energy to stored energy component 150.

[0065] It is possible, as alternative energy sources continue to grow in their relative importance in providing power to consumers and/or industrial power systems, or as more consumers essentially remove themselves from the power grid, it is possible that the "normal" grid may become the "backup" power source (with no generator). The system of FIG. 4 and the method of FIG. 5 could be modified accordingly to account for the social and technological changes resulting from more widespread use of alternative energy sources to meet day-to-day power demands.

[0066] The above-described embodiments are merely exemplary in nature, and are not intended to limit the scope of the invention as set forth in the following claims.

Claims

1. A backup power system (100, 400), the system comprising:

a secondary power source (140);

a stored energy component (150) capable of storing energy therein; and
a controller (130) in data communication with the secondary power source (140) and the stored energy component (150), wherein said controller (130) is configured to:

compare a measured energy level of energy stored within the stored energy component (150) against a first threshold determined by a maximum time necessary for the secondary power source (140) to at least reach a selected minimum power output level, wherein the first threshold is selected so as to ensure that the secondary power source (140) may be brought into service to power the external load (125) powered by the backup power system (100, 400) using less than an amount of power remaining in the stored energy component (150), and
compare the stored energy level to a second threshold greater than the first threshold, said second threshold being selected so as to reduce a number of on/off cycles of the secondary power source (140) during periods of intermittent power fluctuations of a primary power source (140), said controller being controlled (130) and arranged so as to selectively provide power to the external load (125) from one of a primary power source (110), the secondary power source (140), and the stored energy component (150) in response to the comparison with either the first threshold or the second threshold.

2. The system of claim 1, wherein said controller (130) is configured to provide power to said external load (125) from the stored energy component (150) during said periods of intermittent power fluctuation.
3. The system of claim 1, wherein said controller (130) is configured to selectively restore the stored energy level in the stored energy component (150) to at least the second threshold in response to a comparison result indicating that the stored energy level is less than the second threshold.
4. The system of claim 3, wherein said stored energy level in the stored energy component (150) is restored by operatively connecting the secondary power source (140) to the stored energy component (150).
5. The system of claim 3, wherein said controller (130) is configured to selectively restore the stored energy level in the stored energy component (150) to a predetermined energy level greater than the second

threshold.

6. The system of claim 1, wherein, in response to an indication that said stored energy level is not greater than the first threshold, said controller (130) provides one or more signals that energize said secondary power source (140).
7. The system of claim 1, wherein the secondary power source comprises one or more renewable energy sources (410, 420) having intermittent power available therefrom.
8. The system of claim 7, further comprising a second controller (430) configured to monitor and operatively connect the one or more renewable energy resources (410, 420) to the stored energy component (150).
9. The system of claim 1, wherein, if the stored energy level is less than the first threshold, the secondary power source is operatively connected to the stored energy component (150) to increase the level of energy stored therein.
10. The system of claim 9, wherein, if the stored energy level is greater than the first threshold and less than the second threshold, the secondary power source (140) remains operatively connected to the stored energy component (150).
11. A method of making backup power available for a load (125) that receives normal power from a primary power source (110), the method comprising:

comparing a stored energy level in a stored energy component (150) to a first threshold determined by a maximum time necessary for a secondary power source (140) to at least reach a selected minimum power output level, wherein the first threshold is selected so as to ensure that the secondary power source (140) may be brought into service to power the load (125) using less than said stored energy level in the stored energy component (150); comparing the stored energy level to a second threshold greater than the first threshold, said second threshold being selected so as to reduce a number of on/off cycles of the secondary power source (140) during periods of intermittent power fluctuation of the primary power source (110); and in response to the comparison with either the first threshold or the second threshold, selectively commanding a transfer of power to the load (125) from one of the primary power source (110), secondary power source (140), and the stored energy component (150).

12. The method of claim 11, further comprising selectively restoring the stored energy level in the stored energy component (150) to at least the second threshold in response to a comparison result indicating that the stored energy level is less than the second threshold. 5
13. The method of claim 12, wherein said selectively restoring the stored energy level in the stored energy component (150) comprises restoring the stored energy level to a predetermined energy level greater than the second threshold. 10
14. The method of claim 11, wherein the secondary power source comprises one or more renewable energy sources (410, 420) having intermittent power available therefrom. 15
15. The method of claim 14, further comprising commanding the transfer of power from said one or more renewable energy resources (410, 420) to the stored energy component (150) in response to said one or more comparison results. 20

Patentansprüche

1. Backup-Energiesystem (100, 400), wobei das System umfasst:

eine sekundäre Energiequelle (140);
eine Energiespeicherkomponente (150), die Energie darin speichern kann; und
eine Steuerung (130) in Datenkommunikation mit der sekundären Energiequelle (140) und der Energiespeicherkomponente (150),
wobei die Steuerung (130) konfiguriert ist zum:

Vergleichen eines gemessenen Energieniveaus der in der Energiespeicherkomponente (150) gespeicherten Energie mit einem ersten Schwellenwert, der durch eine maximale Zeit bestimmt wird, die erforderlich ist, damit die sekundäre Energiequelle (140) mindestens ein ausgewähltes minimales Energieausgangsniveau erreicht, wobei der erste Schwellenwert so gewählt ist, dass die sekundäre Energiequelle (140) zur Energieversorgung der externen Last (125), die vom Backup-Energiesystem (100, 400) mit Energie versorgt wird, in Betrieb genommen werden kann unter Verwendung von weniger als einer Menge an Energie, die in der Energiespeicherkomponente (150) verbleibt
und
Vergleichen des gespeicherten Energieniveaus mit einem zweiten Schwellenwert,

der größer als der erste Schwellenwert ist, wobei der zweite Schwellenwert so gewählt ist, dass er eine Anzahl von Ein-/Ausschaltzyklen der sekundären Energiequelle (140) während Perioden von intermittierenden Energieschwankungen einer primären Energiequelle (140) reduziert,

wobei die Steuerung gesteuert (130) und so angeordnet ist, dass sie selektiv die externe Last (125) von einem einer primären Energiequellen (110), der sekundären Energiequelle (140) und der Energiespeicherkomponente (150) als Reaktion auf den Vergleich mit entweder dem ersten Schwellenwert oder dem zweiten Schwellenwert mit Energie versorgt.

2. System nach Anspruch 1, wobei die Steuerung (130) konfiguriert ist, der externen Last (125) während der Perioden intermittierender Energieschwankung Energie aus der Energiespeicherkomponente (150) zur Verfügung zu stellen.
3. System nach Anspruch 1, wobei die Steuerung (130) konfiguriert ist, als Reaktion auf ein Vergleichsergebnis, das anzeigt, dass das gespeicherte Energieniveau niedriger als der zweite Schwellenwert ist, selektiv das gespeicherte Energieniveau in der Energiespeicherkomponente (150) auf mindestens den zweiten Schwellenwert wiederherzustellen.
4. System nach Anspruch 3, wobei das gespeicherte Energieniveau in der Energiespeicherkomponente (150) wiederhergestellt wird, indem die sekundäre Energiequelle (140) funktionell mit der Energiespeicherkomponente (150) verbunden wird.
5. System nach Anspruch 3, wobei die Steuerung (130) konfiguriert ist, selektiv das gespeicherte Energieniveau in der Energiespeicherkomponente (150) auf ein vorgegebenes Energieniveau, das größer als der zweite Schwellenwert ist, wiederherzustellen.
6. System nach Anspruch 1, wobei die Steuerung (130) ein oder mehrere Signale bereitstellt, die die sekundäre Energiequelle (140) als Reaktion auf eine Anzeige, dass das gespeicherte Energieniveau nicht größer als der erste Schwellenwert ist, mit Energie versorgen.
7. System nach Anspruch 1, wobei die sekundäre Energiequelle eine oder mehrere erneuerbare Energiequellen (410, 420) umfasst, die eine intermittierende Energie von dort aus zur Verfügung stellen können.
8. Das System nach Anspruch 7, weiter umfassend eine zweite Steuerung (430), die konfiguriert ist, die eine oder mehreren erneuerbaren Energiequellen

(410, 420) zu überwachen und funktionell mit der Energiespeicherkomponente (150) zu verbinden.

9. System nach Anspruch 1, wobei, wenn das gespeicherte Energieniveau kleiner als der erste Schwellenwert ist, die sekundäre Energiequelle funktionell mit der Energiespeicherkomponente (150) verbunden wird, um das darin gespeicherte Energieniveau zu erhöhen.
10. System nach Anspruch 9, wobei, wenn das gespeicherte Energieniveau größer als der erste Schwellenwert und kleiner als der zweite Schwellenwert ist, die sekundäre Energiequelle (140) funktionell mit der Energiespeicherkomponente (150) verbunden bleibt.
11. Verfahren zum Bereitstellen einer Backup-Energie für eine Last (125), die normale Energie von einer primären Energiequelle (110) empfängt, wobei das Verfahren umfasst:

Vergleichen eines gespeicherten Energieniveaus in einer Energiespeicherkomponente (150) mit einem ersten Schwellenwert, der durch eine maximale Zeit bestimmt wird, die erforderlich ist, damit eine sekundäre Energiequelle (140) mindestens ein ausgewähltes minimales Energieausgangsniveau erreichen kann, wobei der erste Schwellenwert so gewählt ist, dass die sekundäre Energiequelle (140) zur Energieversorgung der externen Last (125), in Betrieb genommen werden kann unter Verwendung von weniger als einer Menge an Energie, die in der Energiespeicherkomponente (150) verbleibt;

Vergleichen des gespeicherten Energieniveaus mit einem zweiten Schwellenwert, der größer als der erste Schwellenwert ist, wobei der zweite Schwellenwert so gewählt ist, dass er eine Anzahl von Ein-/Ausschaltzyklen der sekundären Energiequelle (140) während Perioden intermittierender Energieschwankungen der primären Energiequelle (110) reduziert; und selektives Anweisen einer Übertragung von Energie auf die Last (125) von einer der primären Energiequellen (110), der sekundären Energiequelle (140) und der Energiespeicherkomponente (150) als Reaktion auf den Vergleich mit entweder dem ersten Schwellenwert oder dem zweiten Schwellenwert.

12. Verfahren nach Anspruch 11, weiter umfassend das selektive Wiederherstellen des gespeicherten Energieniveaus in der Energiespeicherkomponente (150) auf mindestens den zweiten Schwellenwert als Reaktion auf ein Vergleichsergebnis, das anzeigt, dass das gespeicherte Energieniveau niedriger ist

als der zweite Schwellenwert.

13. Verfahren nach Anspruch 12, wobei das selektive Wiederherstellen des gespeicherten Energieniveaus in der Energiespeicherkomponente (150) das Wiederherstellen des gespeicherten Energieniveaus auf ein vorbestimmtes Energieniveau, das größer als der zweite Schwellenwert ist, umfasst.
14. Verfahren nach Anspruch 11, wobei die sekundäre Energiequelle eine oder mehrere erneuerbare Energiequellen (410, 420) mit einer daraus verfügbaren intermittierenden Energie umfasst.
15. Verfahren nach Anspruch 14, weiter umfassend das Anweisen der Übertragung von Energie von der einen oder den mehreren erneuerbaren Energiequellen (410, 420) auf die Energiespeicherkomponente (150) als Reaktion auf das eine oder die mehreren Vergleichsergebnisse.

Revendications

1. Système d'alimentation de secours (100, 400), le système comprenant :

une source d'alimentation secondaire (140) ;
un composant à énergie stockée (150) capable de stocker de l'énergie à l'intérieur de celui-ci ; et
un dispositif de commande (130) en communication de données avec la source d'alimentation secondaire (140) et le composant à énergie stockée (150),
dans lequel ledit dispositif de commande (130) est configuré pour :

comparer un niveau d'énergie mesurée de l'énergie stockée au sein du composant à énergie stockée (150) par rapport à un premier seuil déterminé par un temps maximum nécessaire à la source d'alimentation secondaire (140) pour au moins atteindre un niveau de production en sortie d'alimentation minimum, dans lequel le premier seuil est sélectionné de façon à s'assurer que la source d'alimentation secondaire (140) peut être mise en service pour alimenter la charge externe (125) alimentée par le système d'alimentation de secours (100, 400) en utilisant moins qu'une quantité de puissance restant dans le composant à énergie stockée (150), et

comparer le niveau d'énergie stockée avec un second seuil supérieur au premier seuil, ledit second seuil étant sélectionné de façon à réduire un nombre de cycles de marche/arrêt de la source d'alimentation secon-

daire (140) pendant des périodes de fluctuations d'alimentation intermittente d'une source d'alimentation primaire (140),

ledit dispositif de commande étant commandé (130) et agencé de façon à fournir sélectivement de l'alimentation à la charge externe (125) à partir d'une parmi une source d'alimentation primaire (110), la source d'alimentation secondaire (140), et le composant à énergie stockée (150) en réponse à la comparaison avec soit le premier seuil soit le second seuil.

2. Système selon la revendication 1, dans lequel ledit dispositif de commande (130) est configuré pour fournir de l'alimentation à ladite charge externe (125) à partir du composant à énergie stockée (150) pendant lesdites périodes de fluctuation d'alimentation intermittente.
3. Système selon la revendication 1, dans lequel ledit dispositif de commande (130) est configuré pour restaurer sélectivement le niveau d'énergie stockée dans le composant à énergie stockée (150) à au moins le second seuil en réponse à un résultat de comparaison indiquant que le niveau d'énergie stockée est inférieur au second seuil.
4. Système selon la revendication 3, dans lequel ledit niveau d'énergie stockée dans le composant à énergie stockée (150) est restauré en connectant de manière opérationnelle la source de puissance secondaire (140) au composant à énergie stockée (150).
5. Système selon la revendication 3, dans lequel ledit dispositif de commande (130) est configuré pour restaurer sélectivement le niveau d'énergie stockée dans le composant à énergie stockée (150) à un niveau d'énergie prédéterminé supérieur au second seuil.
6. Système selon la revendication 1, dans lequel, en réponse à une indication que ledit niveau d'énergie stockée n'est pas supérieur au premier seuil, ledit dispositif de commande (130) fournit un ou plusieurs signaux qui mettent sous tension ladite source d'alimentation secondaire (140).
7. Système selon la revendication 1, dans lequel la source d'alimentation secondaire comprend une ou plusieurs sources d'énergie renouvelable (410, 420) ayant une alimentation intermittente disponible à partir de celle-ci.
8. Système selon la revendication 7, comprenant en outre un second dispositif de commande (430) configuré pour surveiller et connecter de manière opérationnelle les une ou plusieurs ressources d'énergie

renouvelable (410, 420) au composant à énergie stockée (150).

9. Système selon la revendication 1, dans lequel, si le niveau d'énergie stockée est inférieur au premier seuil, la source d'alimentation secondaire est connectée de manière opérationnelle au composant à énergie stockée (150) pour augmenter le niveau de l'énergie stockée à l'intérieur de celui-ci.
10. Système selon la revendication 9, dans lequel, si le niveau d'énergie stockée est supérieur au premier seuil et inférieur au second seuil, la source d'alimentation secondaire (140) reste connectée de manière opérationnelle au composant à énergie stockée (150).
11. Procédé de fabrication d'une alimentation de secours disponible pour une charge (125) qui reçoit une alimentation normale à partir d'une source d'alimentation primaire (110), le procédé comprenant :

la comparaison d'un niveau d'énergie stockée dans un composant à énergie stockée (150) avec un premier seuil déterminé par un temps maximum nécessaire à une source d'alimentation secondaire (140) pour au moins atteindre un niveau de production en sortie d'alimentation minimum sélectionné, dans lequel le premier seuil est sélectionné de façon à garantir que la source d'alimentation secondaire (140) peut être mise en service pour alimenter la charge (125) en utilisant moins que ledit niveau d'énergie stockée dans le composant à énergie stockée (150) ;

la comparaison du niveau d'énergie stockée avec un second seuil supérieur au premier seuil, ledit second seuil étant sélectionné de façon à réduire un nombre de cycles de marche/arrêt de la source d'alimentation secondaire (140) pendant des périodes de fluctuation d'alimentation intermittente de la source d'alimentation primaire (110) ; et

en réponse à la comparaison avec soit le premier seuil soit le second seuil, la commande sélective d'un transfert d'alimentation à la charge (125) à partir d'un parmi la source d'alimentation primaire (110), la source d'alimentation secondaire (140), et le composant à énergie stockée (150).

12. Procédé selon la revendication 11, comprenant en outre la restauration sélective du niveau d'énergie stockée dans le composant à énergie stockée (150) à au moins le second seuil en réponse à un résultat de comparaison indiquant que le niveau d'énergie stockée est inférieur au second seuil.

13. Procédé selon la revendication 12, dans lequel ladite restauration sélective du niveau d'énergie stockée dans le composant à énergie stockée (150) comprend la restauration du niveau d'énergie stockée à un niveau d'énergie prédéterminé supérieur au second seuil. 5
14. Procédé selon la revendication 11, dans lequel la source d'alimentation secondaire comprend une ou plusieurs sources d'énergie renouvelable (410, 420) ayant une alimentation intermittente disponible à partir de celle-ci. 10
15. Procédé selon la revendication 14, comprenant en outre la commande du transfert d'alimentation à partir desdites une ou plusieurs ressources d'énergie renouvelable (410, 420) au composant à énergie stockée (150) en réponse auxdits un ou plusieurs résultats de comparaison. 15
- 20
- 25
- 30
- 35
- 40
- 45
- 50
- 55

FIG. 1




FIG. 2




FIG. 3A




FIG. 3B




FIG. 4





FIG. 5



REFERENCES CITED IN THE DESCRIPTION

This list of references cited by the applicant is for the reader's convenience only. It does not form part of the European patent document. Even though great care has been taken in compiling the references, errors or omissions cannot be excluded and the EPO disclaims all liability in this regard.

Patent documents cited in the description

- US 5642004 A [0002]